



C/39

75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Hospital/2023/SZ/ 1629

Dated:- 07/08/2023

To,
Executive Engineer (E),
PWD Health Maintenance Electrical Division,
South west, Government of Delhi,
Delhi Armed Police Line, Vikas Puri,
New Delhi- 110018.

Sub: - Inspection report of Renewal in R/o: Nehru Homeopathic Medical College and Hospital
Located at B- Block, Defence Colony, New Delhi-110024.

Sir,

Please refer to your letter outdoor dairy No 3148 dated-26.06.2023 on the subject cited above. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on 19/07/2023 in the presence of Dr. Abdul motinmolla (Nodal Officer/Fire Safety) from fire safety point of view. The building comprised of Three Blocks. Main ward & OPD Block= Ground Plus three upper floors, Admin Block= Ground plus three upper floors & Teaching Block= Ground plus two upper floors. Main block and admin Blocks are interconnected at ground floor and first floor only. Following shortcomings were observed during the time of inspection:-

1. Fire fighting system was not functional.
2. Pipes are badly leaking.
3. Some part of building was under renovation.
4. Electric panel not covered at exit way.

Keeping in view of above shortcoming, the application for issuance of Fire Safety Certificate cannot be considered at this stage you are requested to rectify above mentioned shortcoming under intimation to this department for taking necessary action this matter.

Yours faithfully,


(ATUL GARG)
DIRECTOR

Delhi Fire Service

dc

Copy to:-

1. Medical Superintendent, Nehru Homeopathic Medical College and Hospital Located at B-Block, Defence Colony, New Delhi-110024.