

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2023/SZ/ 381
To

Dated: 04.08.2023

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony,
New Delhi 110049.

Sub: Regarding issuance of FSC in r/o M/s Rockland Inn located at B-208, Chittranjan Park, New Delhi-110019

Sir,

This has reference with MHA Portal No 2023070912264 dated 15/07/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 24.07.2023 and observed that the guest house is running at ground plus three upper floors of the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire check doors closing device found missing.
2. Smoke management system not provided in the building as per clause 7.31 of UBBL 2016.
3. Carbon Monoxide detector not provided as per clause 7.31 of UBBL-2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ADULGARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. M/s Rockland Inn located at B-208, Chittranjan Park, New Delhi-110019