

Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F. 6. / DFS / MS / BP / 2023/ 1638

Dated: 08/08/2023

To,

The Medical Superintendent, Nursing Homes, Directorate General of Health Services, Govt. of NCT of Delhi (Nursing Home Cell), 3rd Floor, Delhi Government Dispensary Building, S-1, School Block, Shakarpur, Delhi – 110092.

Sub :- Forwarding the proposed layout plan in respect of Shankuntla Hospital, situated at RZ-1/81, Sagarpur West, New Delhi – 46 for providing guidelines regarding Fire NOC.

Sir

Please refer your letter No. F.24/275/West/DGHS/NHC/2023-26/1263 – 64 dated 12.07.23 on the subject cited above. In this connection it is to inform you that the referred as-built plan of the said hospital has been examined and observed the said hospital is situated at RZ-1/81, Sagarpur West, New Delhi – 46. The building is comprised of basement, ground and four upper floors having a height of 60 feet (18.2 meter). During scrutiny following shortcomings are observed:

 Layout plan showing 6.0 meter wide fire tender movement road and 6.0 meter wide main gate is not provided as per clause 8.2 of UBBL – 2016.

Area chart is not provided.

Staircases, serving form basement, are not segregated on ground floor.

Entry to lift is not through protected lobby as per clause 8.4.4 (j) of UBBL-2016.

5. Entry to staircases is not through Fire Check Doors as per clause 7.11 of UBBL-2016.

Compartmentation is not proposed as per clause 4.5 of NBC-Part-4, 2016.

Width of staircases and corridor is not properly mentioned in meters.

- Dead end travel distance is not meeting the requirement as per clause 7.8.2 of UBBL 2016.
- Exits are violating the clause 7.5.10 of UBBL 2016.
- 10. Under ground fire water tank and pump rooms are not proposed.
- Inspection ladder is not proposed for overhead fire tank.
- 12. Smoke management scheme is not provided.
- 13. Width of patient's / ward room is not mentioned.

Therefore, plans are returned to you in original with request to advice the owner/architect to rectify the above shortcomings and re-submit he proposal for further consideration in the matter.

Encl.: As stated above

Yours faithfully

(Dr. S.K. Tomar)

Dy. Chief Fire Officer

011-23412025

Copy to:

The Medical Superintendent, Shakuntla Nursing Home & Hospital, RZ-I-81A, Sagar Pur (West), (Opp. Delhi Vidyut Board Colony),