

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2023/SZ/308
To

Dated: 07.08.2023

The Principal,
Sarvodaya Kenya Vidyalaya,
Malviya Nagar, New Delhi 110017

Sub: Regarding issuance of FSC in r/o SKV, Malviya Nagar, New Delhi 110017 (ID 1923046)

Sir,

This has reference with letter received through Email dated 13/06/2023 on the subject cited above. In this connection, it is to inform you that the premise have been inspected by officer concerned of this department on 01.08.2023 in the presence of Ms. Jolly Jain (Principal) and observed that there are material changes in the building as addition/ alteration have been made in the building affecting the fire prevention and fire safety measures including the means of escape. Two additional building blocks of ground plus there upper and ground plus two upper floor have been constructed with in the school premises, both old and new blocks are interconnected, previously, the school building comprised of ground plus two upper floors only was issued fire safety certificate by this department vide letter no F6/DFS/MS/SZ/School/2015/SZ/254 dated 24/02/2015. Thus to adjudge the applicability of fire prevention and fire safety measures, the following documents/information are required to be provided.

1. Sanctioned/ Completion plans.
2. As built plan through building/local Authority, if sanctioned/Completion plans are not available.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. You are requested to submit required documents/information for further action in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE