



No. F6 /DFS/MS/ /NDZ/2023/430

Dated: 7/8 /2023

To,

EH

The Manager,
Tesoro Mio Kitchen N Kafe
G-13, 3rd Floor Preet Vihar,
Delhi-110092.

**Sub: - Regarding grant of Fire Safety Certificate in r/o M/s Tesoro Mio Kitchen N Kafe G-13,
3rd Floor Preet Vihar, Delhi_110092.**

Sir,

This has a reference to your Application No. 2023071812707 dated 18.07.2023, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 25.07.2023 in the presence of Mr. Deepanshu Kakkar (Manager) and observed that building comprised of Basement, stilt & Ground + 3 upper floors. (Restaurant is running on 3rd floor of the building).

Following shortcomings were observed during time of inspection:

1. Stand By Fire Pump (Diesel Pump) found removed.
2. Overhead tank of 10,000 liters capacity is provided against the requirement of 50,000 liters.
3. Main Pump & Jockey Pump provided but not functional.
4. Exit Signages found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

e/c AB

Copy to:-

Join Commissioner of police (Lic.), 1st Floor, P.S Defence Colony, New Delhi-24 w.r.t.-
MHA portal ID-2023071812707 Dated-18/07/2023.