



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Storage/2023/SZ/ 1676

Dated:-10/08/2023

To,

Mr. Badal Choudhary (GM)
Aero Retail Logistics Pvt. Ltd.,
ARLPL Warehouse, Land parcel opposite DAFFPL Fule Farm,
GMR Varalakshmi Foundation, Shahbad Mohammadpur,
IGI Airport, New Delhi -110061.

Sub: - Inspection report of Renewal in r/o: Aero Retail Logistics Pvt. Ltd, ARLPL Warehouse, Land parcel opposite DAFFPL Fule Farm, behind GMR Varalakshmi Foundation, Shahbad Mohammadpur, IGI Airport, New Delhi -110061.

Sir,

Please refer to your letter received through Outdoor dairy application no. 1797 dated 09/05/2023 on the subject cited above, in this connection, it is to inform you that the said premises was re- inspected by the team of officers concerned of this department on 01/08/2023 in the presence of Mr. Badal Choudhary (General Manager) from fire safety point of view. The building comprised of Basement (Pump Room), Ground, Mezzanine plus Two upper floors only.

Following shortcomings were observed during the time of inspection:-

1. Sprinkles under ducting areas need to be extended.
2. Main Pumps not on Auto Mode.
3. Loose/hanging wiring seen at some places of building it shall be through conduit/cable tray

In view of above, the application for issuance fire safety certificate is rejected .the occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/statutory authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR

Delhi Fire Service

etc

Copy to:-

1. The Head-MT(P&E),Delhi international Airport Limited, New Udaan Bhawan, opp.Terminal-3 IGI Airport,New Delhi-110037.