



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

Dated: - 09/08/2023

No. F6/DFS/MS/WZ/2023/Sc/322

To,

The Manager,
Indraprastha World School,
A-2, Block, Paschim Vihar,
New Delhi-110063.

Subject: Regarding renewal of Fire Safety Certificate in respect of Indraprastha World School, located at A-2, Block, Paschim Vihar, New Delhi-110063.

Sir,

This has reference to your email dated 12.07.2023 received vide e-mail ID indraprasthaschool@gmail.com, on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officer concerned of this department on 18.07.2023 in the presence of Sh. A Khan (Vice Principal).

During the inspection, it was observed that the building is comprised of Ground + 03 Upper Floors. Fire Safety arrangements such as fire extinguishers, first aid hose reel, & Overhead water storage tank etc found provided. However, the following shortcomings were observed:-

1. The management has installed the Lift in the school building without intimation to this department.
2. Wooden boards used for wall paneling and partitions in the library shall be painted with fire retardant paint.
3. Domestic connection in overhead water storage tank shall be removed. It is exclusively for firefighting purpose.
4. Rooms constructed on terrace shall be removed.
5. One Fire pump capacity 450 LPM for sprinkler system of M.P. Hall found removed.
6. Hose reel in M.P. Hall found removed.
7. Smoke management system in M.P. Hall found removed.
8. Openable window shall be provided in each air conditioned room.
9. Terrace exit/door found locked.
10. Hose reel hose nozzles at some places found missing.
11. Exit signages are non adequate.
12. Curtains in M.P. hall shall be treated with fire retardant material.
13. Atrium covered with PVC coated fabric shall be replaced with metro sheets.
14. Access to overhead tank / Inspection ladder found removed.

In view of the above shortcoming, the application for renewal of Fire Safety Certificate cannot be considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(Atul Garg)
Director

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.