

c-7

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/SZ/2023/ 315

Dated: - 09/08/2023

To,

The Principal,
M.C. Primary School,
Pusa Campus, New Delhi:- 110012.

Sub.:- Regarding issuance of Fire Safety Certificate in r/o M.C. Primary School, Pusa Campus, New Delhi:- 110012.

Sir,

With reference to your letter No. nil, dated 20.07.2023, on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department on 03.08.2023 in your presence to check the fire safety arrangements provided in the school building.

During the course of inspection, it was observed that the school building is comprised of ground floor plus two upper floors. The upper floors are served by two staircases having width of 1.50 mts. each. Fire safety arrangements such as hose reel, fire extinguishers etc. found provided in the school building. However, the following shortcomings were observed:-

1. Three numbers of fire extinguisher found provided against the requirement of six numbers.
2. First aid hose reel provided 02 Nos. at each floor but found not functional.
3. Terrace fire pump capacity of 450 LPM found provided but not functional.
4. Overhead water storage tank capacity of 10,000 lts. provided but found vacant.
5. Exit signage found not provided.

In view of the above, 'Fire Safety Certificate' cannot be issued at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi- 110054 .

For information please.

etc
E