



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/School/ 320

Dated: 09/08/2023

To

The Manager  
S.D. Juniors Play School,  
C-Block, Rajiv Gandhi Road,  
Swaroop Nagar, Delhi-110042.

Sub: - Regarding grant of fire safety certificate in r/o S.D. Juniors Play School located at C-Block, Rajiv Gandhi Road, Swaroop Nagar, Delhi-110042.

Sir,

Please refer to your letter No. SDJPS/01 dated 20.07.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 26.07.2023 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of basement, ground & 03 upper floors only. At the time of inspection Sh. Karamjeet Singh (Admin) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. 01 nos. of staircase provided 1.20m basement & upper floors against the requirements of 02 nos. 1.50m each and needs to be continued from ground to terrace level.
2. Smoke management system not provided in basement & all upper floors.
3. Hose reel hose provided but not functional.
4. MOEFA system not provided.
5. Internal hydrant provided but not functional.
6. Terrace level fire pumps capacity 450lpm not provided.
7. Terrace level fire water tank capacity 10,000ltr not provided.
8. Exit signage's not provided at strategic location in the school building.

Therefore applicant may be requested to apply with complete building plans including fire and life safety provisions as per NBC 2016 through building sanctioning authority for further necessary action in the matter.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Atul Garg)

Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.