

2/29

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2023/Sch/316

Dated: 09/08/2023

To,

The Principal,
St. Mary's Sr. Secondary School,
Sector - 19, Dwarka, New Delhi - 110075.

Subject: Renewal of Fire Safety Certificate in r/o St. Mary's Sr. Secondary School Located at Sector - 19, Dwarka, New Delhi - 110075.

Sir,

Please refer to your letter No. Nil dated 25/07/2023 on the subject mentioned above. In this connection it is to inform you that the premise was re-inspected by the officer from this department on 01/03/2023 in presence of Ms. Seema Bali (V.Pricipal) for fire safety point of view.

During the course of inspection flowing shortcomings were observed.

1. The staircases are found locked at terrace level and plastic furniture & other material found stored in stairs.
2. Wooden cabins are erected in corridors.
3. Canteen found being run at terrace & gas stove are kept in stairs.
4. Ten shed erected at ground floor that is not shown in the plan.
5. Hose reels found not functional.
6. Terrace fire pumps found nonfunctional in auto mode.
7. Exit signage's found removed at some places.

You are requested to comply the above mentioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

(Atul Garg)
Director
Delhi Fire Service

Copy to; - Directorate of Education Old Secretariat Delhi - 110054.