C-5

Dated: 08 08/2023



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/WZ/EH/2023/434

To,

The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. addlcp.lic-dl@nic.in

Sub: - Regarding Issuance of Fire Safety Certificate in r/o M/s. Sunshine Cuisine Located at Shop No. DE.84, UGF, Tagore Garden, New Delhi- 110027.

Sir,

This is in reference to the online application received through MHA portal vide 2023071812747 dated 18/07/2023, regarding issuance of Fire Safety Certificate in respect of aforesaid restaurant. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 28/07/2023 in the presence Sh. Manmohan Singh to check the fire safety arrangements provided in the building.

During inspection, it has been observed that the above restaurant is running at Upper Ground Floor in a building comprised of Basement + Stilt + Upper Ground + 03 Upper floors. Fire safety arrangements such as smoke management system, fire extinguishers, first-aid hose reel, automatic fire detection and alarming system, MOEFA, Internal Hydrant etc provided. However, the following shortcomings were observed.

- 1. Width of staircase is 1x1.50 mts & 1x1.10 to 1.50 mts are provided against requirement of 1.5m x 2.
- 2. Exit doors of width 1 x 1.15 mts & 1 x 1.35 mts are provided against requirement of 1.5 mts x 2.

In view of above shortcomings, the application for Issuance of Fire Safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisite fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

Director

 The Owner/ Occupier M/s. Sunshine Cuisine Located at Shop No. DE.84, UGF. Tagore Garden, New Delhi- 110027.

2. The DHO, MCD, West Zone, Shivaji Enclave, Raja Garden, New Delhi-110027. Email Id: - (dhowest zone@gmail.com)