



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6 /DFS/MS/School/NDZ/2023/ 333

Dated: 11/08/2023

To,

The Principal
MCD Primary Pratibha
Vidyalaya Chandra Vihar -I,
Delhi-110092..

Sub: - Regarding grant of Fire Safety Certificate in r/o MCD Primary Pratibha Vidyalaya Chandra Vihar -I, Delhi-110092.

Sir,

This has a reference to your Outdoor Diary no. 4266 dated - 28.07.2023, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 04/08/2023 in the presence of Mrs. Vijata Trisal (Principal) and observed that building comprised of Ground + 02 upper floors and following shortcomings were observed during time of inspection:

1. Overhead tank capacity 8,000 liters provided against the requirement of 10,000 liters.
2. Hose reel hose provided but non functional.
3. Fire pump of 450 LPM provided but non functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GAING)
DIRECTOR

DELHI FIRE SERVICE

o/c @

Copy to: -

1. Director of Education, MCD, Udyog Sadan, Plot no.419, FIE, Patparganj Industrial Area, Delhi-110092.