



No. F6 /DFS/MS/School/NDZ/2023/ 334

Dated: 11 / 08 / 2023

To,

The Principal
MCD Pry School, Acharya
Niketan, Mayur Vihar,
Phase-1, Delhi-110091.

Sub: - Regarding grant of Fire Safety Certificate in r/o MCD Pry School located at Acharya Niketan, Mayur Vihar, Phase-1, Delhi-110091.

Sir,

This has a reference to your Email date 24.07.2023, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 02/08/2023 in the presence of Mrs. Alka Dhuper (Principal) and observed that building comprised of Ground floor + 02 upper floor.

Following shortcomings were observed during time of inspection:

1. Overhead tank capacity 8,000 liters provided against the requirement of 10,000 liters.
2. Exit Signage's not provided.
3. Hose reel hose provided but non functional.
4. Fire pump of 450 LPM provided but non functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)

DIRECTOR
DELHI FIRE SERVICE

o/c @

Copy to: -

1. Director of Education, MCD, Udyog Sadan, Plot no.419, FIE, Patparganj Industrial Area, Delhi-110092.