

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/2023/ 1689

Dated 12.08.2023

To,

Sh. N .K. Gaur (Fire Officer),
New Delhi Muncipal Council,
Palika Kendra New Delhi.

Sub:- Regarding renewal of FSC in r/o Mohan Singh Place at Baba Kharak Singh Marg, New Delhi.

Sir,

This has reference to your e-mail <fo@ndmc.gov.in> dated 18.07.2023, on the subject cited above. In this connection, it is to inform that the site was inspected by the officers concerned of this department on 31/07/2023 in the presence of Sh. Mahender Shokeen (fire Officer) and the following shortcomings were observed:

1. Fire check doors found removed at some places.
2. Detectors are not provided at some upper floors
3. Sprinklers are not provided at some upper floors.
4. MOEFA and PA system found non functional
5. Lift signage's found removed.

In view of above, the request for renewal of shortcomings is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. Chairman, NDMC, Palika Kendra, New Delhi.
2. The Manager, Mohan Singh Place at Baba Kharak Singh, Marg, New Delhi.