

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/School/2023/SZ/ 335
To

Dated: ..11../..08/2023

The Principal,
New Nanki Public School
48-49, Central Market, Dr. Ambedkar Nagar,
Sector- 5, Dakshin Puri, Delhi 110062

Sub.- Regarding issuance of Fire Safety Certificate in r/o New Nanki Public School at 48-49, Central Market, Dr. Ambedkar Nagar, Sector- 5, Dakshin Puri, Delhi 110062

Sir,

This has reference to your letter received through Outdoor diary no 4034 dated 21/07/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 01/08/2023 in the presence of Mr. S.K Panday. During the inspection it was observed that school is comprised of ground plus four upper floors. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Only one staircase is provided having width of 0.84 mtr. One more staircase is required for upper floors having clear width of 0.75 mtr.
2. First aid hose reels are not provided at each floor.
3. Boosting arrangement for hose reel is not provided. A Fire pump of 450 LPM with a head of 40 m shall be provided.
4. Overhead tank of 10,000 ltrs is not provided at terrace level.
5. Exit signages are not provided.

The school building is comprised of ground plus four upper floors, the management/ owner of the building is hereby directed to submit height verification certificate from MCD, for further action in the matter in accordance with the provision contained in Delhi Fire Service Rules, 2010.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054