



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/EH/2023/SZ/ 1690

Dated: 12/08/2023

To,

Sh. Abhishek Mittal
M/s Pizza Hut (A Unit of Devyani International Ltd),
Shop No.-39, GF, Multi Level Parking cum Commercial Complex (MLCP),
DLF South Square Mall, Sarojni Nagar,
New Delhi-11002

Subject: Regarding issuance of Fire Safety Certificate in r/o- M/s Pizza Hut (A Unit of Devyani International Ltd), Shop No.-39, GF, Multi Level Parking cum Commercial Complex (MLCP), DLF South Square Mall, Sarojni Nagar, New Delhi-110023.

Sir,

Please refer to your MHA application no. 2023073013640 dated 30/07/23 on the subject noted above, in this connection, it is to inform you that the said premises was inspected by the officer concerned of this department on 05.08.2023 in the presence of Mr Prashant Sharma (Sr. Engineer) and observed following shortcoming during the inspection:-

1. Two exit doors having width of 2.00 meter (front side) and 1.66 meter (passing through kitchen) provided & the second exit door/escape route passing through kitchen area which is not acceptable as per the provision contained in UBBL-2016.
2. Fire check door opening in mall side needs to be replaced.(In damaged)
3. Segregate Kitchen with fire check door.

In view of above, the application for issuance Fire Safety Certificate is rejected .the occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/statutory authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Joint Commissioner of Police (Lic.)
Licensing Unit, 1st Floor, Police Station Defence Colony, New Delhi
MHA ID. 2023073013640 dated 30/07/23