

C5

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/EH/WZ/2023/440

Dated: 14/08/2023

To,

The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi.  
[addlcp.lic-dl@nic.in](mailto:addlcp.lic-dl@nic.in)

Subject: Regarding issuance of NOC from fire safety point of view in respect of M/s Chelvies Hospitality Pvt. Ltd., located at House No. 02, First Floor, NWA Road, Punjabi Bagh Extension, New Delhi-110026.

Sir,

Please refer to your online application no. 2023071512589 dated 18/07/2023 on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 03/08/2023 in the presence of Sh. Ayan Khan to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above restaurant is running at First Floor in a Building comprised of Basement, Ground + 03 Upper floors. Fire safety arrangements such as Fire Extinguishers, MOEFA etc are provided. However the following shortcomings were observed.

1. Width of staircase is provided 1 x 1.05m & 1 x .75m against requirement of 2 x 1.5mtr.
2. Width of door size is provided 1 x 1.35m & 1 x 1.0m against requirement of 2 x 1.5mtr.
3. First-Aid Hose Reels & Internal Hydrant is not provided.
4. Terrace level pump capacity of 450 LPM is not provided.
5. Overhead water storage tank capacity of 20,000 ltr is not provided.
6. Exit signages are not provided.
7. The building plan uploaded on MHA Portal is not signed by owner/occupier or registered architect.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the Building/Premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/Occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provided all necessary fire arrangements.

Yours faithfully

(Atul Garg)  
Director

Copy to: -

1. The Owner/Occupier, M/s Chelvies Hoapitality Pvt. Ltd., located at House No. 02, First Floor, NWA Road, Punjabi Bagh Extension, New Delhi-110026.
2. The DHO, MCD, West Zone, Shivaji Enclave, Raja Garden, New Delhi- 110027. ([dhowestzone@gmail.com](mailto:dhowestzone@gmail.com)).