



C-16

75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/2023/SZ/ 340

Dated:- 16/08/2023

To,

Mrs. Sangeeta Zaidi (Principal)
Kendriya Vidyalaya No. IV
Kandhar Line, Delhi Cantt.

Sub: - Inspection report of Renewal in r/o: Kendriya Vidyalaya No. IV, Kandhar Line, Delhi Cantt.

Sir,

Please refer to your letter received through Outdoor dairy application no. 3161 dated 26/06/2023 on the subject cited above, in this connection, it is to inform you that the said premises was re- inspected by the team of officers concerned of this department on 03/08/2023 in the presence of Smt. Sangeeta Zaidi (Principal) from fire safety point of view. The building comprised of Ground floors only.

Following shortcomings were observed during the time of inspection:-

1. Fire Extinguisher provided but not functional.
2. Loose/hanging wiring seen at some places of building it shall be through conduit/cable tray.

In view of above, the building cannot be considered for grant of fire safety certificate at this stage. Therefore you are requested to rectify the above said shortcomings under the intimation to this department for further action.

Yours faithfully


(ATUL GARG)
DIRECTOR

Delhi Fire Service

9/c

Copy:-

1. Director of education, Old Secretariat, Delhi.