

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2023/SZ/1710

Dated: 14/08/2023

To,

The Executive Engineer (E) PWD,
South Elect. Maint. Division, Sukhdev Vihar,
Near Okhla Flyover, New Delhi-110017

Sub: Renewal of Fire Safety Certificate in r/o Lawyer Block, District Court Saket, New Delhi.

Sir,

This is in reference with letter no 23(3) AE (E) 1/South EMD/PWD/1424 dated 10/07/2023 on the subject cited above received from AE (E) PWD. In this regard, it is informed that the premises have been visited by concerned officer of this department on 07/08/2023 in the presence of Mr. Rahul Yadav (JE/Electrical). During inspection, it was observed that Lawyer Block comprised 02 basement ground plus eight upper floors to verify the compliance of fire prevention and fire safety measures required under the rules. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire check doors found close in basement/ lift lobby/ staircase. Self closing device at FCD's are found brokered at some places. Fire rated glass vision in FCD's found broken and need repairing / replacement.
2. Fire extinguisher need to be installed at contain area at ground level.
3. The use of LPG in the building is restricted and not be allowed in any case.
4. Self illuminated Exit Signage's found removed / defective at some strategic location.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:

1. The Hon'ble District Judge (South) District Court Complex, Saket, New Delhi 110017.
2. The Assistant Engineer © PWD BMSSD-1 (M-South) District Court Complex, Saket, New Delhi.
3. The Branch Incharge, Disaster Management Cell, Room No 401, Saket Court Complex, New Delhi.