

c/62

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2023/SZ/ 414
To

Dated: 17.08/2023

The Addl. Commissioner of Police (Lic/Unit),
1st Floor, P.S. Defence Colony,
New Delhi-110049.

Sub: Regarding issuance of FSC in r/o M/s Beyond Hotels located at A-91, Malviya Nagar, New Delhi 110017

Sir,

This is in reference with MHA Portal ID 2023072413142 dated 24/07/2023 on the subject cited above. In this connection, it is to inform you that the premise have been inspected by officer concerned of this department on 26/06/2023 in the presence of Mr. Rahul (Manager) and observed that the Guest House is running in First, Second & Third Floor only. During the course of inspection, the following shortcoming observed were noticed:-

1. Smoke management system not provided as per clause 7.31 of UBBL -2016.
2. Carbon Monoxide detector not provided as per clause 7.31 of UBBL-2016.

The same observation has already been issued and communicated earlier by this department vide letter of even no 314 dated 04.07.2023.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

o/u m