C/23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI- 110001

No. F6/DFS/MS/WZ/EH/2023/ 445

Dated: |7/08 /2023

To,

The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. addlcp.lic-dl@nic.in

Sub: - Regarding issuance of FSC in r/o Epicuria Galley Pvt. Ltd., at Plot No. 10, Ground Floor, Shivaji Place, Distt. Center, Rajouri Garden, New Delhi: - 110027.

Sir,

This is in reference to the online application received through MHA portal vide online ID No. 2023072112952 dated 21/07/2023, on the subject cited above. In this connection, it is to inform you that the premises was re-inspected by officer concerned of this department on 04/08/2023 in the presence Sh. Ashok Yadav to check the shortcomings already issued by this deptt. vide letter No.- F6/DFS/MS/WZ/EH/2022/682 dated: 29/11/2022.

During inspection, it has been observed that said restaurant/eating house is running at ground floor of TDI Epicuria Mall (J.R. Sood & Company Pvt. Ltd.) in a building comprised of 02 Basement, Ground, 04Upper floors was issued FSC by his deptt. vide letter no.-F6/DFS/MS/HQ/2020/95 dated 06/09/2020. Fire safety arrangement of the restaurant such as Fire Extinguishers & Smoke Management System is provided. However, the status of shortcomings is as under.

S. no.	Shortcomings	Status
1.	Sprinkler is required in left out area.	Not Rectified
2.	Detectors system is required in left out area.	Not Rectified
3.	Exit signage's are not provided	Not Rectified

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisite fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,

Director

Copy to: -

1. The Owner/ Occupier M/s Epicuria Galley Pvt. Ltd., at Plot No. 10, Ground Floor, Shivaji Place, Distt. Center, Raouri Garden, New Delhi: - 110027. (Online ID:-2023072112952 dated 21/07/2023).

2. The DHO, West Zone, MCD, Shivaji Enclave, Raja Garden, New Delhi-110027. Email Id: - (dhowest zone@gmail.com).