

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/GH/2023/SZ/ 412

Dated 17/08/2023

To

The Joint Commissioner of Police
Lic/Branch, 1st Floor, Police Station
Defence Colony, New Delhi-110049.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Lloyd House II, Guest House at C-6, Kalkaji, New Delhi -110019.

Sir,

This has reference to your MHA Portal ID 2023072112955 dated 28-07-2023 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 05.08.2023 in the presence of Mr. Ayush (Manager) to verify the fire safety measures installed in the building and observed that the Guest house is running at Ground plus two upper floors. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Temporary structure at terrace with kitchen not allowed at clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(AJAY GARG)
DIRECTOR
DELHI FIRE SERVICE

1/4