



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F.6/DFS/MS/BP/2023/ 173

Dated: 07/08/2023

To,

The Executive Engineer (Bldg.) HQ,
North Delhi Municipal Corporation,
8th Floor, Minto Road,
New Delhi.

Sub: Rejection of building plan in r/o Industrial Occupancy at Plot no. 81, Rajasthan Udyog Nagar, G. T. Road, Delhi.

Sir,

With reference to online request no. 10116544 dated 24.07.2023 on the subject cited above, it is informed that the referred online building plans in respect of proposed industrial building at Plot no. 81, Rajasthan Udyog Nagar, G. T. Road, Delhi were scrutinized under rule 34 of The Delhi Fire Service Rules, 2010 and following shortcomings were observed:-

1. The building plans are not submitted as per clause 2.0.4 of the UBBL-2016.
2. Staircases are not proposed as per UBBL-2016/NBC-2016, Part-IV.

In view of the above, the building plans are rejected with a request to resubmit plans after rectification of above shortcomings for further consideration.

Yours faithfully,



(Atul Garg)

Director

