

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/2023/SZ/ 1768

Dated: 21/08/2023

To
The Authorized Signatory,
Bhandari House at 91, Nehru Place,
New Delhi 110019.

Sub: Regarding Renewal of Fire Safety Certificate in r/o M/s Bhandari House at 91, Nehru Place,
New Delhi 110019.

Sir,

This has reference with your letter no dated 28/06/2023 on the subject cited above. In this concretion it is to inform you that the premise was inspected by the concern officers of this department on 11-08-2023 & observed that the building is comprised of Basement, and Eight upper floors. During the course of inspection, the following shortcoming observed were noticed:-

1. Fire check door provided but found defective and damaged.
2. First Aid hose reel hose found not functional.
3. Automatic fire detection & alarming system provided but found non-functional.
4. MOEFA found removed.
5. Public Address system found removed at some places.
6. Automatic sprinkler system provided but found not functional.
7. Internal hydrant found non functional.
8. Fire fighting pumps provided but found non-functional.
9. Exit Signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Executive Engineer (Bldg) South MCD, Dr. SPM Civic Center, Minto Road, New Delhi 110002