

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2023/ 1770

Dated:-21/08/2023

To

Ms. Neeva Jain, (IPS),
Resident Commissioner,
New Maharashtra Sadan,
K.G. Marg, New Delhi.

Sub: Regarding issuance of FSC in r/o New Maharashtra Sadan, K.G. Marg, New Delhi.

Sir,

This has reference to letter no. **RC/ARC/Audit/2023/2376 dated 25.07.23**, on the subject cited above. In this connection it is to inform you that the site was inspected by the officer concerned of this department on **14/08/2023** in the presence of **Sh. Ashutosh Diwedi** and following shortcomings were observed:-

1. 02 staircases are not provided in foyer as per approved building plan and 02 are found blocked by dumping of waste materials in the staircase.
2. Some fire check doors are found broken.
3. Some hose reels are found nonfunctional.
4. Detectors are not provided in some offices.
5. Terrace tank of 20,000 liter not provided.
6. Exit signages are found inadequate.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings at the earliest for further consideration in the matter.

Yours faithfully


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.