



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/3  
आजादी का  
अमृत महोत्सव

No.F6/DFS/MS/Industrial/SZ/2023/ 1765

Dated: 21/08/2023

To

Mr. Vijay Pratap Singh (Authorized representative),  
M/S Udyog Sheel Mahila Sehkari Samiti Ltd.,  
120, Mathura Road, Opp. Apollo Hospital,  
New Delhi-110076.

**Sub:** -Regarding renewal of Fire Safety Certificate in r/o M/S Udyog Sheel Mahila Sehkari Samiti Ltd., located at 120, Mathura Road, Opp. Apollo Hospital, New Delhi-110076

Sir,

With reference to your email letter dated 25.07.2023 on the subject cited above, it is informed that the said building was inspected by a team of officers concerned from this department on 11.08.2023 in the presence of Mr. Shyam Narayan Bhardwaj (Fire Consultant) and it was observed that the building is comprised of Ground + 3 upper floors. During the inspection the following shortcomings were observed:

1. All Fire Check Doors (FCD) found removed.
2. Automatic Fire Detection and Alarm System (ADAS) found removed in common areas.
3. Exit signages found removed from most of the exit routes.
4. PVC cladding on windows & grills must be removed/replaced by non-combustible material.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully/

(A.P. Garg)  
Director

Delhi Fire Service

16/8/23

Copy to:-

1. The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New Delhi-24.