



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/BB/ 1761

Dated: 21/08/2023

To

The Authorized Signatory
D-1, Virat Bhawan, Mukharji Nagar,
Delhi-110009.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Virat Bhawan Building located at D-1, Mukharjee Nagar, Delhi-110009.

Sir,

This has reference to yours letter no- FOWA/VB-2023-24 dated: 28.07.2023 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 03.08.2023 in the presence of Sh. Abhishek (Manager) to verify the fire safety measures provided in the building in accordance with the provision contain in 12 Minimum Standard for fire prevention & Fire Safety measures and observed that the existing building is comprised of Basement, ground, Mezzanine and 03 upper floors. The following observation/ shortcoming were noticed at the time of inspection:-

1. Fire check doors found removed at some locations in the staircase.
2. Smoke management system found removed in basement.
3. Hose reel hose provided but not functional.
4. Automatic sprinkler system provided in basement but not functional.
5. Internal hydrant provided but not functional.
6. Firefighting pumps capacity of 1620lpm & 450x2 lpm provided but not functional at the time of inspection.
7. Exits signage's found removed at strategic location in the building.

Keeping in view of above observations, the said building is not safe from fire safety point of view & rejected. Hence, you are hereby advised to comply the observations at the earliest under intimation to this department & apply on form 'J' of Delhi Fire Service Rules 2010 under the DFS Act 2010 available of Delhi Fire Service Website.

Running/ Occupancy of the building without Fire Safety Certificate is at the rise & responsibility of the management.

Yours faithfully

(Sd/-) Garg)
Director

Ph:-011-23414000

12/8/23