

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2023/ 1774

Dated: 23/08/2023

To,

The Authorized signatory.
Manipal Hospital (A unit of Human Care Medical Charitable Trust)
Sector-6, Dwarka, New Delhi.

Subject: Renewal of Fire Safety Certificate in r/o Manipal Hospital (A unit of Human Care Medical Charitable Trust) Located at Sector-6, Dwarka, New Delhi

Sir,
Please refer to your Form J dated 19/07/2023 on the subject mentioned above. In this connection it is to inform you that the premises was re-inspected by the officers concerned from this department on 16/08/2023 in presence of Sh. Varun Vats (Fire & Safety Officer) for fire safety point of view..

During course of inspection the following shortcomings were observed:

1. Sealing of shaft found removed at some places.
2. Openable windows found closed by lock and key at some places.
3. Fire check doors found removed/ damaged at some places.
4. Some doors are found permanently closed by lock & key.
5. Exit Signage found removed at some places.
6. Smoke exhaust fan must be provided in the ventilation shafts.
7. Temporary rooms are found erected at terrace.

In view of the above shortcomings renewal of Fire Safety Certificate cannot be considered at this stage.

You are requested to comply the abovementioned shortcomings under intimation to this department for further consideration in the matter.

The FSC issued vide letter No. F6/DFS/MS/2020/Hospital/509 dated 07/12/2020 shall be remain suspended till the compliance of the shortcomings.

Yours faithfully,


(Ajal Garg)
Director
Delhi Fire Service

Copy to:-

1. The MS, Nursing Homes, Directorate General of Health Services, Govt. of NCT of Delhi, S-1, 3rd floor, School Block, Shakarpur, Delhi - 110092.
2. The Joint Director (L&I) Bldg. DDA, Vikas Sadan, INA, New Delhi