



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

No. F. 6. / DFS / MS / BP / CGHS/2023/ 185

Dated: 23/08/2023

To,

The Dy. Director (L&I) Bldg.,  
Delhi Development Authority,  
Vikas Sadan, INA,  
New Delh-110023.

**Sub: Online building plans belonging to Elephant Head CGHS Ltd., Plot No. 41, Sector- 10, Dwarka, New Delhi for Addition / Alteration.**

Sir,

Please refer your online file No. DW10/0074/2023 dated 11.08.2023 on the subject cited above. In this connection it is to inform you that the referred online building plans have been examined by this department from fire and life safety point of view and observed following shortcomings:

1. The 6.0 meter wide fire tender movement road is not proposed in accordance with the previous approved layout plan.
2. Proposed expansion/construction on terrace is not clear.

Therefore, the proposal is rejected.

Yours faithfully

(ATUL GARG)  
DIRECTOR

Ph. 011-23414000

*[Handwritten signature and initials]*