



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE **NEW DELHI- 110 001**

No. F.6/DFS/MS/EH/2023/NDZ/ 459

Dated: 23 08 2023

To.

The Joint Commissioner (Lic.) 1st floor Police Station Defence Colony, New Delhi

Sub:- Regarding Issuance of Fire Safety Certificate in r/o New Chhappan Bhog at V-447, Main Road First Floor Vijay Park Maujpur, Delhi110053.

Sir.

With reference to MHA portal application ID no. 2023072813483 dated 31/07/2023 on the subject cited above. In this connection, it is to inform you that the officers concerned of this department have carried out the inspection of premises from fire safety point of view in presence of Sh. Pawan Aggarwal, Manager on dated 12/08/2023. The building comprised of basement, ground plus three upper floors. Proposed eating house is on first floor only. Following shortcomings were observed during the time of inspection.

- 1. One staircase of width 1.20 meter provided against the requirement of two staircases of width 1.50 meter each.
- 2. One door of width 1.10 meter provided against the requirement of two doors of width 1.50 meter each.
- 3. Kitchen should be segregated by the means of fire check door.
- 4. First Aid hose reel provide but not functional.
- 5. Down-comer/internal hydrant not provided.
- 6. Terrace pump of capacity 450 LPM with 40 meter head not provided.
- 7. Overhead water tank 20,000 liters not provided.
- 8. Exits signage not provided.

In view of above, the application for issuance Fire Safety Certificate is rejected. The occupancy of building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

Copy to:-

Sh. Pawan Aggarwal

New Chhappan Bhog at V-447, Main Road First Floor Vijay Park Maujpur, Delhil 10053.