

C/21

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F.6/DFS/MS/EH/2023/SZ/ 456  
To

Dated: 23/08/2023

*AKA*

The Dy. Health Officer,  
Public Health Department, MCD,  
Central Zone, Lajpat Nager, New Delhi 110024

Sub: Regarding issuance of FSC in r/o M/s Third Wave Coffee (Unit of HEISETASSE BEVERAGES Pvt Ltd) at E -4, Kalkaji, New Delhi 110019

Sir,

This has reference to with MHA Portal ID 2023073113647 dated 31/07/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 14.08.2023 in the presence of Mr. Saurav (Manager) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. There is one Staircase having width of 1.40 mtr against the required two staircase having width of 1.50 mtr each as per UBBL-2016.
2. The exit door having width of 1.0 mtr each against the required minimum widths of two exits are 1.50 mtr each as per UBBL 2016.
3. Overhead tank capacity 5,000 ltrs provided against the required capacity of 20,000 ltrs.
4. Exit Signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

*(Signature)*  
(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. M/s Third Wave Coffee (Unit of HEISETASSE BEVERAGES Pvt Ltd) at E -4, Kalkaji, New Delhi 110019

*only RT copy*