



C-105

75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SZ/2023 /1794

Dated: 24/08/2023

To,
Mr. saurabh sanval
PHD chamber of commerce & industry
at PHD House, 4/2, Siri Institutional Area
August Kranti marg new delhi -110016

Sub: - Regarding grant of FSC from fire safety point of view in r/o: PHD chamber of commerce & industry at PHD House, 4/2, Siri Institutional area August Kranti marg new delhi -110016.

Sir,

Please refer to your letter out dairy No 6203 dated 22.09.2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above-mentioned building in presence of Mr. dinesh (assistant secretary) from fire safety point of view. The building comprised of Basement + Ground+ MEZ + 04 upper floors.

Following shortcomings were observed during the time of inspection:-

1. Fire check door/ smoke door found removed.
2. Terrace tank is under Repair.

In view of above, the building cannot be considered for grant of fire safety certificate at this stage. Therefore you are requested to rectify the above said shortcomings under the intimation to this department for further action.

Yours faithfully

(ATUL GARG)
DIRECTOR
Delhi Fire Service

o/c