

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/BP/2023/184

Dated: 22/08/2023

To,

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
8th floor, Minto Road, New Delhi-110002

Sub: Clearance of **revised building plans** in r/o IT enabled service industry similar to business building, Plot no-18 A, Najafgarh Road, Industrial Area, New Delhi.

Sir,

Please refer your online ID No. 10116804 dated 16.08.2023 on the subject cited above. In this connection, this is to inform you that the revised plans were scrutinized from fire safety point of view and the following shortcomings are observed:

1. The designed of the fire tower is not proposed as per clause 9.3.13 of UBBL-2016/ clause 2.24 of NBC part 4, 2016.

Accordingly, the case is hereby rejected.

Yours faithfully,


(Atul Garg)
Director

011-23414000

W Q 8