

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/Business/NDZ/2023/1854

Dated: 30/08/2023

To,

The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM, Civic Centre, New Delhi - 02.

Sub: Regarding renewal of Fire Safety Certificate in respect of **Akarshan Bhawan** located at **4754-57/23, Ansari Road, Darya Ganj, Delhi.**

Sir,

This has reference on the subject cited above. In this connection, it is to inform you that the building/ premises was inspected by the officer concerned of this department on dated 24.08.2023 in the presence of Mr. Sohan Sigh Slathia (Secretary, ABFOWA). During inspection, the shortcomings communicated vide letter no. F6/DFS/MS/Business/NDZ/2022/3109 dated 13.12.2022 were still exists:

1. Fire extinguishers are due for refilling.
2. First aid hose reel found non functional.
3. Alternate power source for control panel not provided.
4. MOEFA not provided.
5. Public address system found not functional.
6. Automatic sprinkler system in basement found not functional.
7. Pumping arrangements at terrace level found removed.
8. Exit signages are not adequately provided.
9. Over head water storage tank requirement of 50,000 ltrs found removed.
10. Lift signages are not provided.
11. Standby power supply not provided.

In view of above shortcomings, the occupancy of the building /premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The owner/ occupier is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service 01 L
Tel:-011-23414000

Copy to:-

Mr. Sohan Sigh Slathia (Secretary),
Akarshan Bhawan, Flat Owners Welfare Association,
4754-57/23, Ansari Road, Darya Ganj, Delhi - 02.

84
29/8