

c/67

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2023/SZ/ 449
To

Dated: 30/08/2023

The Addl. Commissioner of Police (Lic/Unit),
1st Floor, P.S. Defence Colony,
New Delhi-110049.

Sub: Regarding issuance of FSC in r/o M/s Beyond Hotels located at A-91, Malviya Nagar, New Delhi 110017

Sir,

This is in reference with **MHA Portal ID 2023081814805 dated 18/08/2023** on the subject cited above. In this connection, it is to inform you that the premise have been inspected by officer concerned of this department on 24/08/2023 in the presence of Mr. Rahul (Manager) and observed that the Guest House is running in First, Second & Third Floor only. During the course of inspection, the following shortcoming observed were noticed:-

1. Smoke management system not provided as per clause 7.31 of UBBL -2016.
2. Carbon Monoxide detector not provided as per clause 7.31 of UBBL-2016.

The same observation has already been issued and communicated earlier by this department vide letter of even no 314 dated 04.07.2023 & letter of even no 414 dated 17/08/2023.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

of 14 w