

C6

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2023/WZ/Banquet/ 196

Dated: 29/08/2023

To,

Mr. Manish Goyal,
House No.258-259, 3rd floor,
Pocket-5, Agarsain International Hospital,
Rohini, Sector-22,
Delhi-110085.

Sub: Issue of FSC in r/o M/s City Vatika D. 2A, Kh. No.771, Karan Vihar, Part-5, Suleman Nagar, Delhi-86.

Sir,

This is in reference to your online application No. 2023073013616 dated 31.07.2023 on the subject cited above. The premise was inspected by the concern nominated authority of this department on 21.08.2023, in presence of Mr. Sombir (Owner) to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. Fire protection systems as per Table-7 of NBC-2016 such as Hose-reel, Fire pump, Water tank, Down comer, MOEFA etc. are not provided.
2. Building is not matching with building plans provided in the CAF.
3. Numbers and arrangements of exits like Doors and Staircases are not provided as per UBBL-2016.
4. Direction are required to be issued under Rule 34 of DFS Rules 2010 being a Party Hall Banquet Hall.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt
p://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR
Ph; 011-23414000
JLC
DNY

Copy to:

MHA Portal ID. 2023073013616 dated 31.07.2023.