

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/MS/DFS/Hospital/2023/SZ/ 1819

Dated 28 / 08 / 2023

To

Dr. B.R Sur
Homeopathic Medical Collage,
Hospital & Research Centre Situated,
Nanakpura, Moti Bagh, New Delhi 110021

Sub: -Regarding issuance of FSC in r/o Dr. B.R Sur Homeopathic Medical Collage, Hospital & Research Centre Situated at Nanakpura, Moti Bagh, New Delhi 110021


Sir,

This has reference with letter no F.No-01(1)SHMC/2004-2006/pt/file-II/481 dated 25/07/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 17.08.2023 in the presence of Dr. Neeraj Gupta (Principal/HOD) of Hospital to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

- 1 First aid hose reel provided but found nonfunctional.
- 2 Automatic detection system provided but found nonfunctional.
- 3 MOEFA found removed.
- 4 Public Address system found removed.
- 5 Internal hydrant provided but found nonfunctional.
- 6 Fire fighting pumps provided but found nonfunctional.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


28/8/2023

(VIRENDRA SINGH)
CHIEF FIRE OFFICER (HQ)
DELHI FIRE SERVICE

