

c/36 DFA

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No: F.6/DFS/MS/School/2023/SZ | 361

Dated: 30/08/2023

To,

The Principal,  
Govt. Sarvodaya Kanya Vidyalaya,  
SPS Block, A-Block, Vikas Puri, New Delhi-110018.

Sub: - Regarding issuance of Fire Safety Certificate in r/o. Govt. Sarvodaya Kanya Vidyalaya, SPS Block, A-Block, Vikas Puri, New Delhi-110018.

Sir,

Please refer to Outdoor diary No. 4140 dated 26/07/2023 on the subject cited above. In this regard, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 22/08/2023 to see the compliance of the requisite fire safety measures. Smt. Rajendri Devi (V.Principal) was present and it was observed that the school building is comprised of ground plus three upper floors & MP Hall ground floor only and have following shortcomings.

1. First aid Hose reel provided but not functional.
2. Fire pump having 450 lpm output at 40 m head provided but not functional.
3. Exit Signage's provided but not sufficient.

In view of above, the school building cannot be considered for grant of fire safety certificate at this stage Therefore you are suggested to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours Faithfully,

  
(Abul Garg)  
Director  
Delhi Fire Service

Copy:-

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi-110054.

BT