C-69

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2023/ 432

Dated:-24/08/2023

To

The Manager
M/S Harman Palace Guest House,
1682, Laxmi Narain Street, Pahar Ganj,
New Delhi.

Sub: Regarding issuance of FSC in r/o M/S Harman Palace Guest House at 1682, Laxmi Narain Street, Pahar Ganj, New Delhi.

Sir.

This has reference to online id no. 2023080514029 dated 08/08/23, on the subject cited above. In this connection, it is to inform you that the site was inspected by the officer concerned of this department on 18/08/2023 in the presence of Mr. Arman and following shortcomings were observed:-

1. Hose reel found nonfunctional

2. Pump found nonfunctional and not in auto mode provisions.

No. of rooms as mentioned in the application form does not match with building plan as uploaded.

Further, basement is existing in the building as per building plan uploaded on the portal, whereas in earlier FSC/ NOC & correspondence the basement was not mentioned. Hence, it seems that this is a case of addition alteration, required to be clarified.

In view of above, the case is rejected with a request to comply the above said shortcomings for further consideration in the matter.

Yours faithfully

DIRECTOR Delhi Fire Service

/

Copy to:

1. The Addl. Commissioner of Police (Lic.), First floor, PS Defence Colony, New Delhi.