

C-22

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2023/SZ/ 428
To

Dated: 24/08/2023

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony,
New Delhi 110049.

Sub: Regarding issuance of FSC in r/o M/s Hotel Anutham located at E-147, E Block, Saket, New Delhi 110017.

Sir,

This has reference with **MHA Portal ID 2023080413953** dated **04/08/2023** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 16.08.2023 in the presence of Mr. Suraj (Front Office) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire check doors not provided in the building as per clause 7.31 of UBBL 2016.
2. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

DELHI FIRE SERVICE

Copy to:-

1. M/s Hotel Anutham located at E-147, E Block, Saket, New Delhi 110017