

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
Connaught Place: New Delhi-110001

No. F.6/DFS/MS/2023/BP/ 188

Dated: 28/08/2023

To,

The Executive Engineer (Bldg.) HQ
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road
New Delhi 110002.

Subject: Regarding clearance of building plans from fire safety point of view in r/o
NCUI Complex-3, Siri Institutional Area August Kranti Marg, New Delhi.

Sir,

Please refer your ID No. 10116917 dated 21.08.2023 on the above cited subject. In this connection, this is to inform you that the matter was examined and observed that there is an online proposal for construction of building at NCUI Complex-3, Siri Institutional Area August Kranti Marg, New Delhi. Following shortcoming is observed:-

1. Staircase serving to the basement is not segregated as per clause 7.11(t) of UBBL 2016.
2. Refuge area is not proposed as per 9.3.6, 9.3.7 of UBBL 2016.
3. The capacity of fire pumps is not marked on plans and also not correctly mentioned in CAF as per NBC Part-IV 2016.
4. Information mentioned in sections and plans are mismatching.

Accordingly, the case is rejected.

Yours faithfully

(Atul Garg)
Director

011 23414000

28/08/23