



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

6-12  
7  
आज़ादी का  
अमृत महोत्सव  
4A/FT

No. F6 /DFS/MS/EH/SZ/2023/ 477

Dated: 30/08/2023

To

The Joint Commissioner of Police,  
Office of Joint commissioner of Police: Licensing,  
1st Floor, P S Defence Colony, New Delhi.

**Sub: -Regarding grant of Fire Safety Certificate in r/o M/s Dominos Pizza (Jubilant Foodworks Limited) Situated at Plot no. 16, Ground Floor, Community Centre, Okhla Ph-I, Delhi.**

Sir,

with reference to the Online application ID no. 2023080814201 dated 08.08.2023 on the subject cited above, it is informed that the said restaurant was inspected by a team of officers concerned from this department on 22.08.2023 in the presence of Mr. Ankur (Manager) and it was observed that the restaurant is running at ground floor of the community centre building which is comprised of Basement + Ground + 3 upper floors. During the inspection following shortcomings were observed:

1. Alternate exit having width 1.50 meter must be provided.
2. Hose reel not provided.
3. Manuel Operated Electrical Fire Alarm (MOEFA) system not provided.
4. Internal hydrant system not provided.
5. Fire pump having capacity 450 LPM & head 40 m not provided.
6. Overhead tank capacity 20,000 liters not provided exclusively for fire fighting.
7. Exit signages not provided.
8. Oil filled electrical stabilizer must be relocated away from alternate exit route.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Anuf Garg)

Director

Delhi Fire Service

28/8