

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No.F6/DFS/MS/WZ/2023/ 1858

Dated: - 30/08/2023

To,

Ms. Shivani,
Mahajan Products Pvt. Ltd.,
H-5 Udyog Nagar Industrial Area,
Rohtak Road, Delhi-110041.

Subject: Regarding renewal of Fire Safety Certificate in respect of Mahajan Productis Pvt. Ltd., located at Plot no. H-5, Udyog Nagar Industrial Area, Rohtak Road, Delhi-110041.

Sir,

This has reference to your email dated 21.08.2023 on the subject cited above. In this connection, it is to inform you that the above said building has been inspected by the officer concerned of this department from fire safety point of view on 27.08.2023 in the presence of Ms. Shashi Mahajan (Director). During inspection, it has been observed that the said building is comprised of Basement + Ground + Mezz. Floor + 01 Upper Floor only served with 02 staircases. The Fire safety arrangement such as fire extinguisher, first aid hose reel, automatic sprinkler system, & overhead water storage tank etc found provided. However, the following points have been noticed as shortcomings:-

1. One staircase of Iron made found in width 0.91 m to 0.98 m against 1.2 m.
2. Fire Check Doors found removed.
3. First Aid Hose reel found non-functional.
4. Sprinkler System found non-functional.
5. Sprinkler system to be extended in left out area of basement.
6. Main Fire pump of 1680 lpm & Terrace pump of 450 lpm found removed.
7. Overhead water storage tank only for fire fighting. Domestic connection shall be removed from Overhead water storage tank.
8. Permanent rooms & temporary structure constructed on terrace floor shall be removed.

In view of the above shortcomings, renewal of FSC is not considered at this stage & rejected. You are requested to submit point wise compliance & till such time occupancy of the building/premises in absence of requisite fire safety arrangements shall be at your own risk and responsibility.

Yours faithfully

(Atul Garg)
Director

29/8

29/8/23