

C-22

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/EH/2023/SZ/ 476
To,

Dated: 30/08/2023

The Manager,
M/s Standard Burfee, First Floor,
D-117, Jail Road, Feteah Nagar,
Tilak Nagar, New Delhi-110018.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o M/s Standard Burfee, First Floor, D-117, Jail Road, Feteah Nagar, Tilak Nagar, New Delhi-110018.

Sir,

Please refer to online application ID No. 2023080714177 dated 08/08/2023 on the subject cited above. In this connection this is to inform you that officers concerned of this department inspected the said premises to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Lakshay Arora (Manager) was present and it was observed that the building is comprised of ground floor (Sweet Shop), first Floor (Restaurant), second (vacant) and third floor (workshop) and have following shortcomings:-

1. Second exit having 1 m provided in place of 1.5 m.
2. First aid hose reel provided but not functional.
3. MOEFA provided but not functional.
4. Down comer system provided but not functional.
5. Fire pump provided but not functional at terrace.
6. Overhead water tank 10,000 liters provided in place of 20,000 liters.
7. Exits signage's are not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours faithfully

(Ajit Garg)

Director

Delhi Fire Service

Copy to:-

1. The Joint Commissioner of Police, 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi-110064.