

C-49

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6 /DFS/MS/EH/2023/SZ/ 464
To

Dated: 24/08/2023

The Dy. Health Officer, MCD,
Public Health Department,
Najafgarh Zone, Near Dhasa Bus Stand,
Najafgarh, Delhi 110043

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s Sylvan Chef Vatika located at 1768/1,
Vasant Kunj, Nangal Road, New Delhi 110070.
Sir,

This has reference with **MHA Portal ID 2023042807671** dated **24/07/2023** on the subject cited above. In this regard it is to inform you that the above mentioned site was visited by the officer concerned of this department and observed that there is a temporary structural which is under erection/contraction, hence, the site is not worthies for inspection.

Further, you are advised to forward following documents to this department to ensure proper implementation of fire prevention & fire safety measures as applicable under Rule 33 of DFS-2010 the said premise/building.

1. Sanctioned/ Completion plans.
2. As built plan through building/local Authority, if sanctioned/Completion plans are not available.
3. Initial date of operation of Occupancy in this building.

The same observation has already been issued and communicated earlier by this department vide letter of even no 260 dated 19.05.2023.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

o/a