

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

Dated: 29/08/2023

No. F.6/DFS/MS/GH/2023/SZ/ 446  
To

The Joint Commissioner of Police,  
Lic/Branch, 1<sup>st</sup> Floor, P.S Defence Colony,  
New Delhi 110049

Sub: Regarding issuance of FSC in r/o The R Blues Guest House (A Unit of hotel The R Blues) at  
A-79, NH-8, Mahipalpur Extn. New Delhi- 110037

Sir,

This is in reference with MHA Portal ID No 2023081814831 dated 18/08/2023 & 2023081114459 dated 12/08/2023 on the subject cited above. In this connection, it is inform you that the premises have been inspected by officer concerned of this department on 23/08/2023 in the presence of Mr. Damodar Mishra of the Guest House. During the inspection, it was observed that the guest house is comprised of Basement, Ground + 02 Upper Floor. The shortcomings observed are as below;

1. Fire check door system not provided as per clause 7.31 of UBBL 2016.
2. Smoke management system not provided as per clause 7.31 of UBBL 2016.
3. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

*Virendra Singh*  
25/08/2023  
(VIRENDRA SINGH)  
CHIEF FIRE OFFICER (HQ)  
DELHI FIRE SERVICE

*Virendra Singh*