



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/GH/2023/SZ/1874

Dated: 01/08/2023

To,

Authorized Signatory,
D. A. E. Guest House, Kidwai Nagar (West),
New Delhi-110016.

Subject: Inspection Report in r/o D.A.E. Guest House, Kidwai Nagar (West), New Delhi-16.

Sir,

Please refer to your application no. 080/2015_OCC on the subject cited above, in this connection, it is to inform you that the said premises was re-inspected by the team of officers concerned of this department on 18/08/2023 in the presence of Mr. Anshumaan Shukla (SOD) from fire safety point of view. The building comprised of Basement+ Ground Floor+ Three Upper Floors only.

Following shortcomings were observed during the time of inspection:-

1. The width of staircases are less than the proposed width of 1.5m & 0.875m.
2. Terrace Fire pump of 1620 LPM still not provided.
3. Fire Check doors not provided of the building as per clause 7.31 of UBBL 2016.
4. Carbon Monoxide Detector not Provide as per clause 7.31 of UBBL 2016.
5. Fire Fighting pumps are not auto mode.

In view of above, the application for issuance fire safety certificate is rejected .the occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/statutory authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Delhi Fire Service

AK PA

Copy to :-

1. The Addl. Commissioner of Police (Lic), Licensing Unit, 1st Floor, Police Station, Defence Colony, New Delhi-110049.