



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

446  
7/5  
आज़ादी का  
अमृत महोत्सव

No. F6 /DFS/MS/Industrial/SZ/2023 /1876

Dated: 01/09/2023

To

The Authorized Signatory,  
M/s Multani Pharmaceuticals Ltd,  
Plot no. C-100, Okhla Industrial Area, Phase-I, New Delhi-20.

**Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Multani Pharmaceuticals Ltd, located at Plot no. C-100, Okhla Industrial Area, Phase-I, New Delhi-20.**

Sir,

with reference to your email dated 22.08.2023 on the subject cited above, it is informed that the said building was inspected by officer concerned of this department on 23.08.2023 in the presence of Mr. Sanjeev Kumar Jha (Manager) and it was observed that the building is comprised of **Basement + Ground + Mezzanine (1<sup>st</sup> floor) + 2<sup>nd</sup> floor**. During the inspection following shortcomings were observed:

1. Alternate staircase width not meeting requirement.
2. Alternate exit doorway from basement is not meeting requirements.
3. Basement is not segregated by fire check door.
4. Temporary construction on terrace shall be removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Atul Garg)  
Director

Delhi Fire Service

Copy to:-

The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New Delhi-24.

7/5  
2/18