



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आज़ादी का  
अमृत महोत्सव

CS

No. F6/DFS/MS/WZ/2023 482

Dated:- 31-08-2023

To,

The Joint Commissioner of Police (Lic),  
1<sup>st</sup> Floor, Licensing Unit,  
Police Station, Defence Colony,  
New Delhi.


**Sub.:- Regarding renewal of Fire Safety Certificate in r/o M/s. Agust Foods & Beverages, located at G-2, Pushkar Enclave, Paschim Vihar, New Delhi-110063**

Sir,

This has reference to online application no. 2023072112928 dated 16.08.2023 on the subject cited above. In this connection, it is to inform you that parameters such as numbers of staircase, clear width of staircase, clear width of door & clear width of corridor etc. uploaded on MHA portal application are not matching with the building. Drawing uploaded on MHA portal is not <sup>readable</sup> visible. The building sanctioned plans or as built plans uploaded in the MHA portal, shall be signed by Regd. Architect & Owner/Occupier of the building or sanctioning authority i.e. MCD/DDA.

In view of above, the application for issuance of fire safety certificate is not considered at this stage & rejected. You are advised to direct the applicant to re-apply on MHA portal with correct details/information. The occupancy of the building/premises in absence of requisite fire safety measures shall be at the own risk and liabilities of the owner/occupier.

Yours faithfully,

  
(Atul Garg)  
Director  
29/8  
28/8/23

Copy to:-

1. Sh. Naresh Mittal, M/s. Agust Foods & Beverages, G-2, Pushkar Enclave, Paschim Vihar, New Delhi-110063.