

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

Dated:- 31/08/2023

No. F6/DFS/MS/WZ/2023/ 366

To,

The Principal, Bhatnagar International Summit, A-1, Paschim Vihar, New Delhi.

## Subj .:- Regarding renewal of Fire Safety Certificate in respect of Bhatnagar International Summit, located at A-1, Paschim Vihar, New Delhi.

Sir,

Please refer to your Form 'J' dated 20.07.2023, on the subject cited above. In this connection, it is to inform you that the said building have been inspected by the officer concerned of this department on 23.08.2023 in the presence of Ms. Isha Yadav (Principal) to check compliance of shortcomings issued by this department vide letter no. F6/DFS/MS/2019/5020 dated 20.08.2019.

During the course of inspection, it has been observed that the school management has rectified some of the shortcomings, the status is under:-

<u>S.</u> no.	Shortcomings	<u>Status</u>
1.	Tin Shed Rooms on the terrace must be removed/dismantled	Not rectified
2.	Only one staircase of width 1.4 m is provided Ground to 1 <sup>st</sup> floor. One more staircase of width 1.5 m required to be provided from <b>Ground Floor to Terrace</b>	Not rectified (Provided only Ground to 1st floor)
3.	Fire protection system such as Fire Pumps, Hose Reel Hose and Sprinkler in Basement were found nonfunctional	Rectified
4.	Over Head Tank found empty	Rectified

In view of the above, the application for renewal of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcomings under intimation to this department & till such time occupancy of the building/premises in absence of requisite fire safety arrangements shall be at your own risk and responsibility.

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Del 110054.